

# SWM/PCSM FACILITY-BMP O&M - Yearly Self Inspection

## GENERAL INFORMATION

Facility/BMP Type(s)		BMP#	
Location		Township	
Facility/BMP Owner/Operator			
Inspector's Name			
Signature			
Date of Inspection			

## MAINTENANCE SCORE REFERENCE

Based on the BMP condition, check the appropriate box based on your facilities condition:

N/A - indication a component may not exist in a facility/BMP.

No deficiencies identified.

**Monitor** – Although maintenance may not be required at this time, a potential problem exists that will most likely need to be addressed in the future. This can include items like minor erosion, concrete cracks/spalling, or minor sediment accumulation. This item should be revisited at the next inspection.

**Routine Maintenance Required** – Some inspection items can be addressed through the routine maintenance program. This can include items like vegetation management or debris/trash removal.

**Immediate Repair Necessary** – This item needs immediate attention because failure is imminent or has already occurred, or facility is not functioning as designed. This could include items such as structural failure of a feature (outlet, weir, manhole, etc.), significant erosion, or significant sediment accumulation. This score should be given to an item that can significantly affect the function of the facility.

Please indicate where an issue exists in the comments section below the existing issues. (ie: on a structure, berms of the facility, inlets, etc). Additionally, feel free to email or attach images of problem areas.

Please return Township inspection sheet to our municipal engineer via mail or email:

David Miller Associates Inc  
attn: Jasmine Lee  
1076 Centerville Rd.  
Lancaster, PA 17601

JLee@dmai.com  
attn: Municipal Yearly Inspection Form

# Hydrodynamic/Water Quality Devices

DEFECT	CONDITIONS WHEN MAINTENANCE IS NEEDED	No Deficiencies	Monitor	Maintenance Required	Immediate Repairs Needed
<b>General</b>					
Sediment/Debris/Trash	Sediment, trash, or debris has accumulated in the inlet, sump, or outlet.				
Standing Water	Manufactured treatment device does not drain within 5 days after rainfall.				
Contaminants	Any evidence of oil, gasoline, or other hazardous materials and contaminants.				
Mosquitoes	Evidence of mosquitoes, standing water, or mosquito larvae.				

**COMMENTS:**